

ROYCE CROSS GROUP

TEST REPORT

Product No. 20160414-2

Product Name Three Phase Asynchronous Motor

Model MSHE801-2 0.75kW

Examinee ROYCE CROSS GROUP.

Checkout Sort Periodic Test

Report Date 2016-04-14

ROYCE CROSS GROUP
TESTING CENTER

ROYCE CROSS GROUP

TEST REPORT

Report No. : 20160414-2

page of

Product Type Name	MSHE801-2 Three Phase Asynchronous Motor			Ser.No.	3-32
Rated Output	0.75 kW	Rated Voltage	400 V	Rated Current	1.8 A
Rated Speed	2800 r/min	Rated Frequency	50 Hz	Insulation Class	F
Duty	S1	Protection Class	IP55	Connection	Y
Product Standard		Testing Standard	GB/T1032-2012	Production Date	
Test Item		Eligibility Value		Test Value	Test Result
		Standard	Tolerance		
1. Stator resistance at 25°C	Ω	/	/	9.0348	/
2. No load current	A	/	/	1.05	/
3. No load current deviation	%	≤10	/	3.64	Passed
4. No load input power	W	/	/	94.7	/
5. Locked rotor current	A	/	/	11.44	/
6. Locked current/Rated current		≤6.8	+1.36	6.73	Passed
7. Locked torque	N m	/	/	7.71	/
8. Locked torque/Rated torque		≥2.0	-0.30	3.10	Passed
9. Full load current	A	/	/	1.70	/
10. Rated torque	N m	/	/	2.490	/
11. Max. torque	N m	/	/	/	/
12. Max. torque/Rated torque		/	/	/	/
13. Min. torque	N m	/	/	/	/
14. Min. torque/Rated torque	N m	/	/	/	/
15. Full load speed	r/min	/	/	2875.8	/
16. Output power	W	/	/	750	/
17. Input power	W	/	/	964.9	/
18. Efficiency	%	≥77.4	-3.39	77.73	Passed
19. Power factor		≥0.83	-0.02	0.817	Passed
20. Stator winding temp.rise	K	≤80	/	39.4	Passed
21. Ambient temperature	°C	/	/	19.51	/
22. Bearing temperature	°C	≤95	/	42	Passed
23. Stator core temperature	°C	/	/	41.20	/
24. Insulation resistance warmly to frameM Ω		/	/	/	/
25. Vibration	mm/s	/	/	/	/
26. Noise	dB(A)	/	/	/	/
27. High voltage test	V min	1800	/	/	/
28.					
29.					
30.					
Conclusion					

Tested by

Checked by

Formed

2016-04-14