

ROYCE CROSS GROUP

TEST REPORT

Product No. 20150918-1

Product Name Three Phase Asynchronous Motor

Model MSHE100L-6 1.5kW

Examinee ROYCE CROSS GROUP.

Checkout Sort Periodic Test

Report Date 2015-09-18

ROYCE CROSS GROUP
TESTING CENTER

ROYCE CROSS GROUP

TEST REPORT

Report No. : 20150918-1

page of

Product Type Name	MSHE100L-6 Three Phase Asynchronous Motor			Ser.No.	07-03P2
Rated Output	1.5 kW	Rated Voltage	400 V	Rated Current	4.0 A
Rated Speed	945 r/min	Rated Frequency	50 Hz	Insulation Class	F
Duty	S1	Protection Class	IP55	Connection	Y
Product Standard		Testing Standard	GB/T1032-2012	Production Date	
Test Item	Eligibility Value		Test Value	Test Result	
	Standard	Tolerance			
1. Stator resistance at 25°C	Ω	/	/	0.0000	/
2. No load current	A	/	/	2.31	/
3. No load current deviation	%	≤10	/	2.82	Passed
4. No load input power	W	/	/	162.2	/
5. Locked rotor current	A	/	/	22.10	/
6. Locked current/Rated current		≤6.0	+1.20	6.16	Passed
7. Locked torque	N m	/	/	33.03	/
8. Locked torque/Rated torque		≥2.1	-0.31	2.20	Passed
9. Full load current	A	/	/	3.59	/
10. Rated torque	N m	/	/	14.993	/
11. Max. torque	N m	/	/	/	/
12. Max. torque/Rated torque		/	/	/	/
13. Min. torque	N m	/	/	/	/
14. Min. torque/Rated torque	N m	/	/	/	/
15. Full load speed	r/min	/	/	955.4	/
16. Output power	W	/	/	1500	/
17. Input power	W	/	/	1869.9	/
18. Efficiency	%	≥79.8	-3.03	80.22	Passed
19. Power factor		≥0.74	-0.043	0.753	Passed
20. Stator winding temp.rise	K	≤80	/	61.7	Passed
21. Ambient temperature	°C	/	/	22.13	/
22. Bearing temperature	°C	≤95	/	50	Passed
23. Stator core temperature	°C	/	/	59.90	/
24. Insulation resistance warmly to frameM Ω		/	/	/	/
25. Vibration	mm/s	/	/	/	/
26. Noise	dB(A)	/	/	/	/
27. High voltage test	V min	1800	/	/	/
28.					
29.					
30.					
Conclusion					

Tested by

Checked by

Formed

2015-09-18