

ROYCE CROSS GROUP

TEST REPORT

Product No. 20141211-1

Product Name Three Phase Asynchronous Motor

Model MSHE112M-4 4.0kW

Examinee ROYCE CROSS GROUP.

Checkout Sort Periodic Test

Report Date 2014-12-12

ROYCE CROSS GROUP
TESTING CENTER

ROYCE CROSS GROUP

TEST REPORT

Report No. : 20141211-1

page of

Product Type Name	MSHE112M-4 Three Phase Asynchronous Motor			Ser.No.	
Rated Output	4.0 kW	Rated Voltage	400 V	Rated Current	8.0 A
Rated Speed	1430 r/min	Rated Frequency	50 Hz	Insulation Class	F
Duty	S1	Protection Class	IP55	Connection	Y
Product Standard		Testing Standard	GB/T1032-2012	Production Date	
Test Item	Eligibility Value		Test Value	Test Result	
	Standard	Tolerance			
1. Stator resistance at 25°C	Ω	/	/	0.0000	/
2. No load current	A	/	/	3.98	/
3. No load current deviation	%	≤10	/	4.59	Passed
4. No load input power	W	/	/	250.3	/
5. Locked rotor current	A	/	/	63.83	/
6. Locked current/Rated current		≤7.7	+1.54	7.84	Passed
7. Locked torque	N m	/	/	69.23	/
8. Locked torque/Rated torque		≥2.3	-0.34	2.63	Passed
9. Full load current	A	/	/	8.14	/
10. Rated torque	N m	/	/	26.299	/
11. Max. torque	N m	/	/	/	/
12. Max. torque/Rated torque		/	/	/	/
13. Min. torque	N m	/	/	/	/
14. Min. torque/Rated torque	N m	/	/	/	/
15. Full load speed	r/min	/	/	1452.4	/
16. Output power	W	/	/	4000	/
17. Input power	W	/	/	4622.8	/
18. Efficiency	%	≥86.6	-2.01	86.53	Passed
19. Power factor		≥0.82	-0.030	0.820	Passed
20. Stator winding temp.rise	K	≤80	/	53.8	Passed
21. Ambient temperature	°C	/	/	15.99	/
22. Bearing temperature	°C	≤95	/	59.0	Passed
23. Stator core temperature	°C	/	/	58.50	/
24. Insulation resistance warmly to frameM Ω		/	/	/	/
25. Vibration	mm/s	/	/	/	/
26. Noise	dB(A)	/	/	/	/
27. High voltage test	V min	1800	/	/	/
28.					
29.					
30.					
Conclusion					

Tested by

Checked by

Formed

2014-12-12