

ROYCE CROSS GROUP

TEST REPORT

Product No. 20131024-3

Product Name Three Phase Asynchronous Motor

Model MSHE132M-4 7.5kW

Examinee ROYCE CROSS GROUP.

Checkout Sort Periodic Test

Report Date 2013-10-25

ROYCE CROSS GROUP
TESTING CENTER

ROYCE CROSS GROUP

TEST REPORT

Report No. : 20131024-3

page of

Product Type Name	MSHE132M-4 Three Phase Asynchronous Motor			Ser.No.	
Rated Output	7.5 kW	Rated Voltage	400 V	Rated Current	16.0 A
Rated Speed	1400 r/min	Rated Frequency	50 Hz	Insulation Class	F
Duty	S1	Protection Class	IP55	Connection	△
Product Standard		Testing Standard	GB/T1032-2005	Production Date	
Test Item	Eligibility Value		Test Value	Test Result	
	Standard	Tolerance			
1. Stator resistance at 25°C	Ω	/	/	0.0000	/
2. No load current	A	/	/	6.11	/
3. No load current deviation	%	≤10	/	3.54	Passed
4. No load input power	W	/	/	401.1	/
5. Locked rotor current	A	/	/	127.30	/
6. Locked current/Rated current		≤7.4	+1.48	8.67	Passed
7. Locked torque	N m	/	/	144.62	/
8. Locked torque/Rated torque		≥2.0	-0.30	2.95	Passed
9. Full load current	A	/	/	14.69	/
10. Rated torque	N m	/	/	49.056	/
11. Max. torque	N m	/	/	/	/
12. Max. torque/Rated torque		/	/	/	/
13. Min. torque	N m	/	/	/	/
14. Min. torque/Rated torque	N m	/	/	/	/
15. Full load speed	r/min	/	/	1460.0	/
16. Output power	W	/	/	7500	/
17. Input power	W	/	/	8513.5	/
18. Efficiency	%	≥88.7	-1.70	88.10	Passed
19. Power factor		≥0.83	-0.028	0.836	Passed
20. Stator winding temp.rise	K	≤80	/	59.1	Passed
21. Ambient temperature	°C	/	/	18.81	/
22. Bearing temperature	°C	≤95	/	67.0	Passed
23. Stator core temperature	°C	/	/	66.40	/
24. Insulation resistance warmly to frameM Ω		/	/	/	/
25. Vibration	mm/s	/	/	/	/
26. Noise	dB(A)	/	/	/	/
27. High voltage test	V min	1800	/	/	/
28.					
29.					
30.					
Conclusion					

Tested by

Checked by

Formed

2013-10-25